

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 09/01/2022 - 09/30/2022

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.8	Avg	9.7	Avg	9.7	
		Max	9.9	Max	9.9	Max	9.7	
		Min	9.7	Min	9.6	Min	9.6	
Total Alkalinity	mg/L as CaCO3	Avg	58	Avg	61	Avg	65	
		Max	67	Max	72	Max	70	
		Min	52	Min	52	Min	60	
Total Hardness	mg/L as CaCO3	Avg	87	Avg	90	Avg	90	
		Max	96	Max	101	Max	94	
		Min	78	Min	82	Min	84	
Total Solids	mg/L	Avg	170	Avg	192	Avg	201	
		Max	182	Max	204	Max	222	
		Min	156	Min	180	Min	184	
Total Chloramines	mg/L	Avg	2.67	Avg	2.59	Avg	2.67	
		Max	2.90	Max	2.85	Max	2.75	
		Min	2.50	Min	2.30	Min	2.55	
Total Organic Carbon	mg/L	Avg	2.62	Avg	2.45	Avg	2.34	
		Max	2.74	Max	2.65	Max	2.44	
		Min	2.48	Min	2.27	Min	2.26	
Conductivity	umhos/cm	Avg	303	Avg	313	Avg	360	
		Max	306	Max	313	Max	360	
		Min	299	Min	313	Min	360	
Total Trihalomethanes	ug/L	Avg	38.3	Avg	38.1	Avg	23.5	
		Max	40.9	Max	38.1	Max	23.5	
		Min	35.6	Min	38.1	Min	23.5	
Turbidity	NTU	Avg	.06	Avg	.03	Avg	.03	
		Max	.09	Max	.08	Max	.06	
		Min	.04	Min	.02	Min	.02	