

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 8/1/2020 - 8/31/2020

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP
		Avg		Avg		Avg	
pH	SU	Max	9.8	Max	9.7	Max	9.7
		Min	9.6	Min	9.4	Min	9.6
		Avg	9.7	Avg	9.6	Avg	9.7
Total Alkalinity	mg/L as CaCO3	Max	82	Max	81	Max	63
		Min	60	Min	53	Min	56
		Avg	71	Avg	59	Avg	60
Total Hardness	mg/L as CaCO3	Max	109	Max	109	Max	85
		Min	84	Min	80	Min	79
		Avg	97	Avg	86	Avg	83
Total Chloramines	mg/L	Max	2.90	Max	2.80	Max	2.85
		Min	2.50	Min	2.50	Min	2.70
		Avg	2.76	Avg	2.74	Avg	2.76
Total Organic Carbon	mg/L	Max	2.64	Max	2.32	Max	2.36
		Min	2.35	Min	2.04	Min	2.13
		Avg	2.45	Avg	2.18	Avg	2.19
Conductivity	umhos/cm	Max	309	Max	299	Max	325
		Min	308	Min	299	Min	325
		Avg	309	Avg	299	Avg	325
Total Trihalomethanes	ug/L	Max	27.5	Max	34.3	Max	22.9
		Min	22.8	Min	34.3	Min	22.9
		Avg	25.2	Avg	34.3	Avg	22.9
Turbidity	NTU	Max	0.12	Max	0.04	Max	0.06
		Min	0.03	Min	0.01	Min	0.02
		Avg	0.05	Avg	0.02	Avg	0.03

Due to Covid-19 the number of parameters analyzed has been reduced effective 3-27-20.