

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 5/1/2020 - 5/31/2020

Parameter	Units		Davis WTP		Ullrich WTP		Handcox WTP
pH	SU	Avg	9.7	Avg	9.6	Avg	9.6
		Max	9.7	Max	9.6	Max	9.6
		Min	9.6	Min	9.5	Min	9.6
Total Alkalinity	mg/L as CaCO3	Avg	63	Avg	54	Avg	63
		Max	68	Max	57	Max	68
		Min	60	Min	51	Min	59
Total Hardness	mg/L as CaCO3	Avg	89	Avg	83	Avg	86
		Max	94	Max	84	Max	90
		Min	87	Min	82	Min	82
Total Chloramines	mg/L	Avg	2.79	Avg	2.70	Avg	2.89
		Max	2.90	Max	2.75	Max	3.10
		Min	2.65	Min	2.65	Min	2.70
Total Organic Carbon	mg/L	Avg	2.54	Avg	2.27	Avg	2.42
		Max	2.61	Max	2.34	Max	2.44
		Min	2.46	Min	2.21	Min	2.39
Total Trihalomethanes	ug/L	Avg	29.1	Avg	31.2	Avg	30.6
		Max	30.0	Max	31.2	Max	30.6
		Min	28.2	Min	31.2	Min	30.6
Turbidity	NTU	Avg	0.03	Avg	0.04	Avg	0.02
		Max	0.09	Max	0.05	Max	0.06
		Min	0.02	Min	0.02	Min	0.01

Due to Covid-19 the number of parameters analyzed has been reduced effective 3-27-20.